

Display energy certificate (DEC)



HM Government

Royal Festival Hall
Belvedere Road, The South Bank Centre
LONDON
SE1 8XX

Operational rating

D

Certificate number: 0258-3258-0137-3428-5400

Valid until: 31 March 2027

Total useful floor area: 33,175 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C		
76-100	D	81 D	
			----- 100 -----
101-125	E		
126-150	F		
150+	G		

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	180.80	127.22
Typical energy use (kWh/m ² /year)	150	360.88
Energy from renewables	0%	0%

Previous operational ratings

Date	Operational rating
April 2026	81 D
April 2025	73 C
April 2024	55 C

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
April 2026	3,299	819	0
April 2025	3,226	568	0
April 2024	1,742	1,037	0

Assessment details

Assessor's name	Mehmet Olgun
Employer/Trading name	EQUANS Services Limited
Employer/Trading address	4Th Floor 6 Bevis Marks, Moorgate EC3A 7AF
Assessor's declaration	Contractor to the occupier for EPBD services only.
Accreditation scheme	CIBSE Certification Limited
Issue date	16 March 2026
Nominated date	1 April 2026

