

Display energy certificate (DEC)



HM Government

Southbank Centre
Southbank Centre
Belvedere Road
LONDON
SE1 8XX

Operational rating

E

Certificate number: 0256-6267-6137-4418-6890

Valid until: 31 March 2027

Total useful floor area: 4,292 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C		
76-100	D		
			100
101-125	E	105 E	
126-150	F		
150+	G		

Previous operational ratings

Date	Operational rating
April 2026	105 E
April 2025	100 D
April 2024	124 E

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
April 2026	218	106	0
April 2025	241	74	0
April 2024	251	134	0

Assessment details

Assessor's name	Mehmet Olgun
Employer/Trading name	EQUANS Services Limited
Employer/Trading address	4Th Floor 6 Bevis Marks, Moorgate EC3A 7AF
Assessor's declaration	Contractor to the occupier for EPBD services only.
Accreditation scheme	CIBSE Certification Limited
Issue date	16 March 2026
Nominated date	1 April 2026

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	92.44	127.22
Typical energy use (kWh/m ² /year)	95	103.09
Energy from renewables	0%	0%

