

Display energy certificate (DEC)



HM Government

Southbank Centre Hayward Gallery Southbank Centre Belvedere Road LONDON SE1 8XX	Operational rating F	Certificate number: 4434-5017-9222-7225-8206 <hr/> Valid until: 31 March 2027 <hr/> Total useful floor area: 8,827 square metres
--	--	--

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO2) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C		
76-100	D		
----- 100 -----			
101-125	E		
126-150	F	126 F	
150+	G		

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m2/year)	120.07	127.22
Typical energy use (kWh/m2/year)	70	171.86
Energy from renewables	0%	0%

Previous operational ratings

Date	Operational rating
April 2026	126 F
April 2025	109 E
April 2024	131 F

Total carbon dioxide (CO2) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO2.

Date	Electricity	Heating	Renewables
April 2026	583	218	0
April 2025	554	151	0
April 2024	555	276	0

Assessment details

Assessor's name	Mehmet Olgun
Employer/Trading name	EQUANS Services Limited
Employer/Trading address	4Th Floor 6 Bevis Marks, Moorgate EC3A 7AF
Assessor's declaration	Contractor to the occupier for EPBD services only.
Accreditation scheme	CIBSE Certification Limited
Issue date	16 March 2026
Nominated date	1 April 2026

