

Display energy certificate (DEC)



HM Government

Southbank Centre
The Queen Elizabeth Hall
Belvedere Road
LONDON
SE1 8XX

Operational rating

D

Certificate number: 2424-1045-6174-4308-4025

Valid until: 31 March 2025

Total useful floor area: 7,798 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C		
76-100	D	76 D	
			100
101-125	E		
126-150	F		
150+	G		

Previous operational ratings

Date	Operational rating
April 2024	76 D
April 2023	80 D
April 2022	76 D

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
April 2024	667	244	0
April 2023	665	292	0
April 2022	626	303	0

Assessment details

Assessor's name	Jonathan Crowley
Employer/Trading name	EQUANS Services Limited
Employer/Trading address	Level 20, 25 Canada Square, London, E14 5LQ
Assessor's declaration	Contractor to the occupier for EPBD services only.
Accreditation scheme	CIBSE Certification Limited
Issue date	21 May 2024
Nominated date	1 April 2024

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	155.57	161.20
Typical energy use (kWh/m ² /year)	150	362.32
Energy from renewables	0%	0%