

Display energy certificate (DEC)



HM Government

Arts Council England
Longside Gallery
Jebb Lane
Haigh
BARNSLEY
S75 4BS

Operational rating

C

Certificate number: 5748-5813-8359-7692-6696

Valid until: 31 March 2022

Total useful floor area: 1900.4 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

| Score | Operational rating | This building | Typical |
|---------|--------------------|---------------|---------|
| 0-25 | A | | |
| 26-50 | B | | |
| 51-75 | C | 68 C | |
| 76-100 | D | | 100 |
| 101-125 | E | | |
| 126-150 | F | | |
| 150+ | G | | |

Previous operational ratings

| Date | Operational rating |
|------------|--------------------|
| April 2021 | 68 C |
| April 2020 | 71 C |
| April 2019 | 90 D |

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

| Date | Electricity | Heating | Renewables |
|------------|-------------|---------|------------|
| April 2021 | 69 | 13 | 0 |
| April 2020 | 68 | 15 | 0 |
| April 2019 | 91 | 16 | 0 |

Assessment details

| | |
|--------------------------|---|
| Assessor's name | Jonathan Crowley |
| Employer/Trading name | ENGIE Services Limited |
| Employer/Trading address | Level 20, 25 Canada Square, London, E14 5LQ |
| Assessor's declaration | Not related to the occupier. |
| Accreditation scheme | CIBSE Certification Limited |
| Issue date | 29 April 2021 |
| Nominated date | 1 April 2021 |

This building's energy use

| Energy use | Electricity | Other fuels |
|---|-------------|-------------|
| Annual energy use (kWh/m ² /year) | 65.89 | 29.32 |
| Typical energy use (kWh/m ² /year) | 49.82 | 184.09 |
| Energy from renewables | 0% | 0% |