

Display energy certificate (DEC)



HM Government

Southbank Centre
Southbank Centre - Office
Belvedere Road
LONDON
SE1 8XX

Operational rating

D

Certificate number: 2996-1935-9609-3106-2391

Valid until: 31 March 2022

Total useful floor area: 4292 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C		
76-100	D	93 D	
----- 100 -----			
101-125	E		
126-150	F		
150+	G		

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	80.50	126.21
Typical energy use (kWh/m ² /year)	95	111.19
Energy from renewables	0%	0%

Previous operational ratings

Date	Operational rating
April 2021	93 D
April 2020	159 G
April 2019	157 G

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
April 2021	190	105	0
April 2020	344	156	0
April 2019	334	161	0

Assessment details

Assessor's name	Jonathan Crowley
Employer/Trading name	ENGIE Services Limited
Employer/Trading address	Level 20, 25 Canada Square, London, E14 5LQ
Assessor's declaration	Contractor to the occupier for non-EPBD services.
Accreditation scheme	CIBSE Certification Limited
Issue date	29 April 2021
Nominated date	1 April 2021